



# WRc Testing Certificate

This product met the requirements of WIS 4-34-07 Specification for leak tightness testing of cured-in-place-pipe lining systems for gravity sewer rehabilitation.

## Name of Product

BRAWOLINER® Lining System

## Company

BRAWO SYSTEMS GmbH  
Blechhammerweg 13-17  
67659 Kaiserslautern  
Germany

## Testing Undertaken

Testing of the BRAWOLINER® Lining System, installed by BRAWO SYSTEMS GmbH, was carried out by WRc at the Engineering Test Facility in Swindon in accordance with WIS 4-34-07 for Type C and Type A systems.

## Lining System Tested

Carrier material: BRAWOLINER®  
Resin system: BRAWO® III  
End seal: N/A  
Connection Collar: N/A

## Summary of Test Results

Test 1 (Type C, Liner only):	Class 1
Test 2 (Type A, Liner with reopened lateral):	Class 1
Test 3 (Type B, Liner with connection collar):	N/A

Assessor:

Director:

Issue Date:

4th February 2026

Certificate Number:

TS/026/0226

This certificate only applies to the carrier material and resin quoted above. It does not apply to any other combination of sleeve or resin. Please contact the supplier for further information.