



WRc Testing Certificate

This product met the requirements of WIS 4-34-07 Specification for leak tightness testing of cured-in-place-pipe lining systems for gravity sewer rehabilitation.

Name of Product

LatWrap Lining System

Company

Lateral Repairs UAB
Paberziu g.5
Taurage, Lithuania
LT-72328

Testing Undertaken

Testing of the LatWrap Lining System, installed by Lateral Repairs UAB, was carried out by WRc at the Engineering Test Facility in Swindon in accordance with WIS 4-34-07 for Type C, Type A and Type B systems.

Lining System Tested

Carrier material: Megaliner
Resin system: LatWrap Mega
End seal: N/A
Connection Collar: LatWrap Connection Collar

Summary of Test Results

Test 1 (Type C, Liner only):	Class 1
Test 2 (Type A, Liner with reopened lateral):	Class 1
Test 3 (Type B, Liner with connection collar):	Class 1

Assessor:

Director:

Issue Date:

5th December 2024

Certificate Number:

TS/017/1224

This certificate only applies to the carrier material and resin quoted above. It does not apply to any other combination of sleeve or resin. Please contact the supplier for further information.