



WRc Testing Certificate

This product met the requirements of WIS 4-34-07 Specification for leak tightness testing of cured-in-place-pipe lining systems for gravity sewer rehabilitation.

Name of Product

Impreg GL16 Reinforced Fibreglass Lining System

Company

Impreg (UK) Ltd
12 Acorn Business Park
Portsmouth
PO6 3TH

Testing Undertaken

Testing of the Impreg GL16 Reinforced Fibreglass Lining System, installed by McAllister Group, was carried out by WRc at the Engineering Test Facility in Swindon in accordance with WIS 4-34-07 for a Type C system.

Lining System Tested

Carrier material: GL 16
Resin system: Synthopan UIN 5985 & AOC L720-IMP – 05
End seal: Pipe Aid Fast Cure
Connection Collar: N/A

Summary of Test Results

Test 1 (Type C, Liner only):	Class 1
Test 2 (Type A, Liner with reopened lateral):	N/A
Test 3 (Type B, Liner with connection collar):	N/A

Assessor:

Director:

Issue Date: 15th January 2025

Certificate Number: TS/020/0125

This certificate only applies to the carrier material and resin quoted above. It does not apply to any other combination of sleeve or resin. Please contact the supplier for further information.