



# WRC Testing Certificate

This product met the requirements of WIS 4-34-07 Specification for leak tightness testing of cured-in-place-pipe lining systems for gravity sewer rehabilitation.

## Name of Product

SAERTEX-LINER®

## Company

SAERTEX multiCom GmbH  
Brochterbecker Damm 52  
D-48369 Saerbeck  
Germany

## Testing Undertaken

Testing of the SAERTEX-LINER®, installed by McAllister Group, was carried out by WRC at the Engineering Test Facility in Swindon in accordance with WIS 4-34-07 for a Type C system.

## Lining System Tested

Carrier material: Epros Fibre Glass Mat  
Resin system: Synthopan UIN 1569  
End seal: Pipe Doctor  
Connection Collar: N/A

## Summary of Test Results

Test 1 (Type C, Liner only):	Class 2 [1%]
Test 2 (Type A, Liner with reopened lateral):	N/A
Test 3 (Type B, Liner with connection collar):	N/A

Assessor:

Director:

Issue Date:

22nd January 2025

Certificate Number:

TS/021/0125

This certificate only applies to the carrier material and resin quoted above. It does not apply to any other combination of sleeve or resin. Please contact the supplier for further information.