



# WRc Testing Certificate

This product met the requirements of WIS 4-34-07 Specification for leak tightness testing of cured-in-place-pipe lining systems for gravity sewer rehabilitation.

## Name of Product

Novapipe

## Company

Applied Felts  
Castle Bank Mills, Portobello Road  
Wakefield, W. Yorkshire  
WF1 5PS

## Testing Undertaken

Testing of the Novapipe, installed by Vortex Lining Division, was carried out by WRc at the Engineering Test Facility in Swindon in accordance with WIS 4-34-07 for Type C and Type A systems.

## Lining System Tested

Carrier material: Applied Felts PUXR  
Resin system: Quad-Cure 90 Parts A and B  
End seal: N/A  
Connection Collar: N/A

## Summary of Test Results

Test 1 (Type C, Liner only):	Class 1
Test 2 (Type A, Liner with reopened lateral):	Class 1
Test 3 (Type B, Liner with connection collar):	N/A

Assessor:

Director:

Issue Date: 20th November 2024

Certificate Number: TS/023/1024

This certificate only applies to the carrier material and resin quoted above. It does not apply to any other combination of sleeve or resin. Please contact the supplier for further information.