



WRc Testing Certificate

This product met the requirements of WIS 4-34-07 Specification for leak tightness testing of cured-in-place-pipe lining systems for gravity sewer rehabilitation.

Name of Product

Inpipe UV CIPP Full Length GFRP Liner System

Company

Inpipe Sweden AB
Ekorrvägen 12,
912 32, Vilhelmina
Sweden

Testing Undertaken

Testing of the Inpipe UV CIPP Full Length GFRP Liner System, installed by USSR Limited, was carried out by WRc at the Engineering Test Facility in Swindon in accordance with WIS 4-34-07 for a Type C system.

Lining System Tested

Carrier material: Ultrapipe
Resin system: Palatal
End seal: Masterstop SK MasterMastic PU Quellpaste
Connection Collar: N/A

Summary of Test Results

Test 1 (Type C, Liner only):	Class 1
Test 2 (Type A, Liner with reopened lateral):	N/A
Test 3 (Type B, Liner with connection collar):	N/A

Assessor:

Director:

Issue Date: 19th February 2025

Certificate Number: TS/024/0225

This certificate only applies to the carrier material and resin quoted above. It does not apply to any other combination of sleeve or resin. Please contact the supplier for further information.